

Riverside Community College District

Safety Survey Recommendations – Status Report

Norco College

CSRM Safety Survey Date: October 26, 2018

ITEM	ROOM	RECOMMENDATION	STATUS (i.e. completed, in process)	ANTICIPATED COMPLETION DATE
1	Operations Center	Repair/Replace nonfunctioning Automatic/Power assisted door. ADAAG 404.3.5		
2	Operations Center	Remove accumulated waste materials. Provide process to control and maintain vegetation clearance requirements. CCR, Title 19. Section 304		
3	Operations Center	Maintain minimum 36-inch clearance in front of all electrical panels. NEC 110-26(A)(1). Repair damaged Electrical equipment.		
4	Operations Center	Organize/remove excess storage - potential trip hazards as well as excess combustibles.		
5	Operations Center	Remove excess storage from around compactor equipment. Area should be clear to prevent trips and falls.		
6	Operations Center	Remove acidic bird droppings to prevent damage to industrial machinery. Not only is the equipment being damaged, but workers are exposed to a dangerous health-risk any time they work on or around the machinery.		
7	Operations Center	Equipment not in use should be de-energized to prevent damage/injury accidental start-up.		
8	Operations Center 157	Organize and secure items stored overhead to prevent from falling. Organize storage. Potential trip hazard as well as excess combustibles. Permanent aisles, ladders, stairways, and walkways shall be kept reasonably clear and in good repair. CCR Title 8, 3272(c)		
9	Operations Center	Remove storage from on/around microwave ovens.		
10	Operations Center	Remove storage from on/around Thermostats.		
11	Operations Center	Provide regular maintenance inspections according to guidelines in water intrusion plans. Inspect/repair water lines for loose hardware or leaks.		
12	Operations Center	Remove storage from Fire Riser Room. IFC 901.4.6, IFC 509.2		
13	Operations Center	Secure ladders to prevent from falling. CCR. Title 8, 2940.6(d)		
14	Operations Center	Label all secondary chemical containers. CCR. Title 8, 5194(f)(6)		
15	Operations Center	Appliances shall be connected directly to permanently installed receptacle. CFC 605.4-5		
16	Operations Center	Eyewash stations shall be maintained and free of items which obstruct their use. CCR. Title 8, 5162(c). Store all flammables chemicals in flammables storage cabinet with secondary containment. Title 8, 5164(a)		
17	Operations Center	Stop and emergency stop pushbuttons shall be continuously operable and readily accessible. NFPA 79, 10.7.1		
18	Operations Center	Facilities shall be provided for protecting charging apparatus from damage by mobile equipment. Mobile equipment shall be properly		

		positioned, and brake applied before attempting to change or charge batteries. CCR Title 8, 5185(i)		
19	Operations Center	Permits are required for air tanks over 125 gallons. Permit exceptions depend on vessel capacity and operating pressures. The permit shall be posted under glass in a conspicuous place on or near the air tank or in a weatherproof container secured to the unit and shall be available at all times to any qualified inspector. CCR Title 8, 461(c)		
20	Operations Center	Secure ladders to prevent from falling. CCR. Title 8, 2940.6(d). Permanent aisles, ladders, stairways, and walkways shall be kept reasonably clear and in good repair. Where, due to lack of proper definition, such aisles or walkways become hazardous, they shall be clearly defined by painted lines, curbing, or other method of marking. CCR Title 8, 3272(c)		
21	Operations Center	Exits shall be maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. CCR Title 8, 3225(1)		
22	Operations Center	Secure ladders to prevent from falling. CCR. Title 8, 2940.6(d). Permanent aisles, ladders, stairways, and walkways shall be kept reasonably clear and in good repair. Where, due to lack of proper definition, such aisles or walkways become hazardous, they shall be clearly defined by painted lines, curbing, or other method of marking. CCR Title 8, 3272(c)		
23	Operations Center	Maintain minimum 36-inch clearance in front of all electrical panels. NEC 110-26(A)(1).		
24	Operations Center	Compressed gas cylinders shall be stored or transported in a manner to prevent them from creating a hazard by tipping, falling or rolling. CCR Title 8, 4650(e)		
25	Operations Center	The employer shall provide portable fire extinguishers and shall mount, locate and identify them so that they are readily accessible to employees without subjecting the employees to possible injury. CCR Title 8, 6151(c)(1)		
26	Operations Center	The rated capacity of all industrial lift trucks and industrial tractors shall be displayed at all times on the vehicle in such a manner that it is readily visible to the operator. CCR Title 8, 3660(a). Must include attachments that will affect load center of gravity.		
27	Operations Center	Secure ladders to prevent from falling. CCR. Title 8, 2940.6(d)(D)		
28	Operations Center	Remove flexible power cords used in place of permanent wiring. as a substitute for the fixed wiring of a structure. CCR Title 8, 2500(a)(1). Bundle and constrain cords and cables under/around workstations. Eliminate use of piggy-backed power strips and extension cords. NFPA Section 11.1.4		
29	Operations Center	Organize and secure items stored overhead to prevent from falling. Organize storage. Potential trip hazard as well as excess combustibles. Permanent aisles, ladders, stairways, and walkways shall be kept reasonably clear and in good repair. CCR Title 8, 3272(c)		